



SCM125ZM-S

12.5kW

Specifications

Power source			1Phase, 220 - 240V, 50Hz
Nominal cooling capacity (Min~Max)		kW	12.5(1.8~14.0)
Nominal heating capacity (Min~Max)		kW	13.5(1.5~14.0)
Power consumption	Cooling/Heating	kW	3.90(0.65~4.80) / 3.25(0.70~3.42)
EER/COP	Cooling/Heating		3.21 / 4.15
Max. running current		A	29
Sound power level	Cooling	dB(A)	69
	Heating		72
Sound pressure level	Cooling	dB(A)	57
	Heating		60
Air flow	Cooling	m ³ /min	75.0
	Heating		82.0
Exterior Dimensions	Height x Width x Depth	mm	945 x 970(+73) x 370
Net weight		kg	92.0
Refrigerant	Type/GWP		R410A/2088
	Charge	kg/TCO ₂ Eq	6.0/12.528
Refrigerant piping size	Liquid/Gas	ø mm	6.35(1/4") x 6 / 9.52(3/8") x 6
Outdoor operating temperature range	Cooling	°C	-15~43
	Heating		-15~24
Number of Connectable indoor units			Min.4*~Max.6
Total indoor units capacity			19.5

- The data is measured under the following conditions(ISO-T1, H1). Cooling: Indoor temp. of 27°CDB, 19°CWB, and outdoor temp. of 35°CDB. Heating: Indoor temp. of 20°CDB, and outdoor temp. of 7°CDB, 6°CWB.
- Sound level indicates the value in an anechoic chamber. During operation these values are somewhat higher due to ambient conditions.
- 'tonne(s) of CO₂ equivalent' means a quantity of greenhouse gases- expressed as the product of the weight of the greenhouse gases in metric tonnes and of their global warming potential.
- In case of SRK71ZR + SRK71ZR, 2 Indoor units can be connectable. The total connecting capacity of indoor units should be between 100 – 160.

Schematics

SCM125ZM-S

Symbol	Content
A	Service valve connection (gas side) $\phi 9.52 (3/8")$ (Flare)
B	Service valve connection (liquid side) $\phi 6.35 (1/4")$ (Flare)
C	Pipe/cable draw-out hole
D	Drain discharge hole $\phi 20 \times 3$ places
E	Anchor bolt hole M10 $\times 4$ places

Notes

- (1) It must not be surrounded by walls on the four sides.
- (2) The unit must be fixed with anchor bolts. An anchor bolt must not protrude more than 15mm.
- (3) Where the unit is subject to strong winds, lay it in such a direction that the blower outlet faces perpendicularly to the dominant wind direction.
- (4) Leave 1m or more space above the unit.
- (5) A wall in front of the blower outlet must not exceed the units height.
- (6) The model name label is attached on the rear panel.

