



Installation guide

Back up power module




Wiring Diagram



B

nfo for UK customers only: Danfoss Ltd., 22 Wycombe End, HP9 1NB,





Technical specifications

Nominal input voltage	24 V DC / 24 V AC	
Input voltage range	20 - 40 V DC, 19 - 29 V AC	
Frequency	DC / AC 50 60 Hz + /-10%	
Overvoltage capability	< 42 V DC < 30 V AC	
Nominal input power	DC: 15 VA, AC: 25 VA	
Protection class	Ш	
Inrush current	< 15 A	
Standby current @ 24 V DC	~ 0.1 A	
Nominal output voltage (U _{NOM})	24.0 V DC ± 2%	
Nominal output current (I _{NOM})	2 A	
Maximum output current on standby	30 mA	
Current limiting	2.5 A ± 10%	
Parallel connection for time increase	yes	
Series connection	no	
Capacitor charging current @ 24 V DC	< 1 A	
Charging time	~ 2.5 min from fully discharged state	
Max Voltage / current at X2 (open collector)	24V / 8.5 mA	
Ambient temperature during operation	$T_{AMB} = -25 ^{\circ}C - + 60 ^{\circ}C$	
Storage temperature	- 30 °C - + 70 °C	
Humidity	< 90 % rH, no condensation.	
Environmental pollution	Type 2	
Protection degree	IP 20	
Altitude	Up to 2000 m	
Immunity to voltage Surges EN 61000-4-5	Level 3 in/out Level 2 signals	
Assembly	On DIN rail	
Overvoltage protection	Category II	
Lifespan	>90000 hours (10 years) @ 35 °C and >3 years @ 50 °C	
MTBF	> 500.000 h @ 25 °C according to IEC 61709 / SN 29500	



Recommended Load Switch Position				
Valve Type	Number of valves			
	1 Valve	2 Valves		
ETS 5M / ETS 6	POS B	POS A		
ETS Colibri	POS B	POS B		
ETS 12.5 to 100, ETS 250, ETS 400	POS B	POS B		
KVS 15/42	POS B	POS B		
CCMT / CCM	POS B	POS A		

Important Notes :

. Load switch POS A and POS B defines the max energy supplied by the EKE 2U as power backup.

- . POS A delivers more energy than POS B. Using at POS B further increases lifetime of EKE 2U.
- . Load switch has default position POS A and POS A will work throughout all combinations.

State of Health (SOH)	Function	LEDs
Ready	Backup is ready and controller can start operating valves.	Green on Red off
Charge	Backup module is charging. Controller must not operate valves.	Green flashing. 1 Hz Red off
Replace	Backup module needs to be replaced. But valves can be operated.	Green: Ready or Charge Red on.
Failure	Backup module does not work. Controller can still operate valves. But at a power loss no guarantee that the valves can close.	Green off Red flashing. 1Hz

Cable length

EKE 2U supports the following max. cable length.

	Cable length [m]	Wire size min. / max. [mm²]
Power supply Input	max. 5	0.2 / 1.5
Backup output	max. 5	0.2 / 1.5
Digital outputs	max. 5	0.2 / 1.5

Cable and wiring

• Keep power and battery backup cable separate from SOH cable



General features and warnings

Plastic housing features

-DIN rail mounting

-Self-extinguishing V0

Other features

- -Operating conditions CE: -25T60, 90% RH non-condensing -Storage conditions: -30T70, 90% RH non-condensing
- -Max duty-cycle Charge/Discharge at nominal load 15min ON / 10s OFF
- -To be integrated in Class I and/or II appliances

-Index of protection: IP 20

- Period of electric stress across insulating parts: long
- -Suitable for using in a normal pollution environment
- -Immunity against voltage surges: category II

Safety and approvals

This product is designed to comply with the following standards:

- -EN61000-6-1, EN61000-6-3 (immunity for residential, commercial and light-industrial environments) -EN61000-6-2, EN61000-6-4 (immunity and emission standard for industrial environments)
- -UL 61010

-IEC 61010-2-201:2013

General warnings

- -Every use that is not described in this manual is considered incorrect and is not authorized by the manufacturer
- -Verify that the installation and operating conditions of the device respect those specified in the manual, especially concerning the supply voltage and environmental conditions
- -This device contains live electrical components. All service and maintenance operations must therefore be performed by qualified personnel -The device must not be used as a safety device
- -Liability for injury or damage caused by the incorrect use of the device lies solely with the user
- -The manufacture's guarantee expires in the event of improper use

Installation warnings

- -Intended mounting position: vertical
- -Installation must comply with local standards and legislation
- -Before working on the electrical connections, disconnect the device from the main power supply
- -Before carrying out any maintenance operations on the device, disconnect all electrical connections
- -For safety reasons the appliance must be fitted inside an electrical panel with no live parts accessible
- -Do not expose the device to continuous water sprays or to a relative humidity greater than 90% Avoid exposure to corrosive or pollutant gases, natúral elements, environments where explosives or mixes
 of flammable gases are present, dust, strong vibrations or shock, large and rapid fluctuations in ambient temperature that might cause condensation in combination with high humidity, strong magnetic and/or radio interference (e.g. transmitting antennae)
- When connecting loads be aware of the maximum current for each relay and connector
- -Use cable ends suitable for the corresponding connectors. After tightening connector screws, tug the cables gently to check their tightness
- Use appropriate data communication cables. Refer to the EKE data sheet for the kind of cable to be used and setup recommendations
- -Minimize the length of probe and digital input cables as much as possible and avoid spiral routes around power devices. Separate from inductive loads and power cables to avoid possible electromagnetic noises -Avoid touching or nearly touching the electronic components fitted on the board to avoid electrostatic discharges
- -Use copper cables for operating temperatures >75 °C (ambient temperature \leq 60 °C)

Product warnings


- Use a class II category transformer for 24 V AC power supply
- Connecting any output signals to mains voltage will permanently damage the controller






DIN rail mounting / demounting

The unit can be mounted onto a 35 mm DIN rail simply by snapping it into place and securing it with a stopper to prevent sliding. It is demounted by gently pulling the stirrup located in the base of the housing.




Sharing Power supply and SOH signal

- Power sharing is allowed between EKE 2U power backup module and EKE SH controllers provided power supply is DC.
- Max 2 EKE controller should be connected to 1 EKE 2U
- SOH signal should not be shared. It should be connected to only one EKE controller and the readouts should be taken from this controller.



Danfoss



Related products

Power Supply	EKE series controllers	Stepper motor valves
AK-PS Input: 100 – 240 V AC, 45 – 65 Hz Output: 24 V DC: available with 18 VA, 36 VA and 60 VA ACCTRD	EKE series preprogrammed superheat controllers/ drivers for controlling electric expansion valves.	EKE is compatible with Danfoss stepper motor valves i.e Danfoss ETS 6, ETS, KVS,ETS Colibri®, KVS colibri®, CTR, CCMT
Input: 230 V AC, 50 – 60 Hz Output: 24 V AC, available with 12 VA, 22 VA and 35 VA		

© Danfoss | Climate Solutions | 2021.09